

CORRIGENDUM**PRE- BID MEETING QUERRY REPLY 07.03.2024 VIDE
RFP NO RFP/PB/SOLAR/127/23-24 dt 27.02.2024**

SI	Vendor Name	Query Raised By the Vendor	Banks Reply
(1)	Ecosolis ANI	Time of completion is mentioned 45 days- is it include departmental approvals like Technical feasibility & net metering process time period. It may take more time for approvals.	The whole project to be completed as per the schedule & tender terms and condition.
(2)	Ecosolis ANI	The make of Solar panel other than mentioned in tender document but equivalent having all related certifications & listed in ALMM is acceptable? (Ex. Renewsys/Goldi/ Jakson/Emmvee etc	Bidder to comply with RFP terms
(3)	Ecosolis ANI	The make of Inverter other than mentioned in tender document but equivalent having all related certifications are acceptable? (Ex. Polycab/ Havells/ Growatt/Vsole etc)	Modified Make- Fuzi/ ABB/ Solis/ Delta/ Polycab
(4)	BSSE (I) Pvt Ltd	Net Meter cost	Bidder to comply with RFP terms and it will be in the scope of the contractor
(5)	BSSE (I) Pvt Ltd	True south is not necessary at Port Blair region	It is necessary as to get maximum solar power generation
(6)	BSSE (I) Pvt Ltd	PCU: The capacity of the Inverter shall be chosen based on the PV system wattage. However, the total Peak output Power rating of all the PCU"s at operating temperatures of 45 deg C shall not be less than 100 KW.	Bidder to comply with RFP terms
(7)	BSSE (I) Pvt Ltd	RMS+ Data Logger, Data Monitoring System, The monitoring of the Solar system and logging / viewing of system data shall be done through a PC with	Bidder to comply with RFP terms



		HMI software to be supplied by the Contractor	
(8)	BSSE (I) Pvt Ltd	MMS	Module mounting structure is as mentioned in the tender
(9)	BSSE (I) Pvt Ltd	Annual Generation Guarantee Contractor shall give minimum annual power generation guarantee of each plant for first year (Calculation to be given by the contractor) and for subsequent years as per following – 2nd Year : 99.0% of 1st Year Generation 3rd Year : 98.5% of 1st Year Generation 4th Year : 98.0% of 1st Year Generation 5th Year : 97.5% of 1st Year Generation.	Bidder to comply with RFP terms
(10)	BSSE (I) Pvt Ltd	Load bearing capacity of the sheet roofing for bearing the load of proposed SPV modules has to be ascertained through a recognized Structural Engineer and certificate from Structural Engineer has to be submitted by the Contractor to the Bank before the commencement of the work.	Bidder to comply with RFP terms and it is essential.
(11)	BSSE (I) Pvt Ltd	Channel material & accessories Mounting types of roof mounted on sheet roofing capable of withstanding 200 Km/hr wind speed	Bidder to comply with RFP terms
(12)	BSSE (I) Pvt Ltd	Make- BIS Certified Mono Perc cut cell modules Solar Panel Adani/ Warri/ Tata/HR Solar/ Exide/ (540 watt) Ongrid 33KW Solar On Grid Inverter- Fuzi/ ABB/ Solis/ Delta	Bidder to comply with RFP terms

