



(प्रधान कार्यालय: बेंगलुरु / HEAD OFFICE: BENGALURU)

CORRIGENDUM

FOR

TENDER REF. NO.: PUCO/GA/TNDR/2024-25/SOLAR/CP/001 dtd 12.09.2024

SUPPLY, INSTALLATION, TESTING, COMMISSIONING & MAINTENANCE OF 10 kWp ON- GRID ROOFTOP SOLAR PHOTO VOLTAIC POWER PLANT AT BANK'S RESIDENTIAL APARTMENT BUILDING "CAN PARK SOCIETY" IN PUNE DISTRICT, MAHARASHTRA.

Minutes of pre-bid meeting held at Circle Office, Pune on 21.09.2024

Following changes may be noted and effected in the aforementioned RFP:

S. No.	Document & Pg. No.	Existing Description	Revised Description
1	RFP Page No. 67 of 89 Mechanical Features 2 nd Point	Anodized Aluminum Frame shall be provided around the module.	Mild Steel Frame shall be provided around the module with zinc primer and at least 2 coats of aluminum paint.
2	RFP Page No. 68 of 89 2. Module Mounting Structure Point No. iv.	The array structure shall be made of hot dip galvanized MS angles/anodized aluminum of size not less than 50 mm x 50 mm x 6 mm size. The superstructure should be of GI with Epoxy Industrial Paint and Basic solar PV model structure with HDGI (Hot dip galvanized Iron). 	The array structure shall be made of hot dip galvanized MS angles of size not less than 50 mm x 50 mm x 6 mm size with zinc primer and at least 2 coats of aluminum paint. The superstructure should be of Mild Steel (MS) with zinc primer and at least 2 coats of aluminum paint.
3	RFP Page No. 68 of 89 2. Module Mounting Structure Point No. iv.	PCC ARRAY FOUNDATION BASE: The legs of the structures made with GI angles.....	PCC ARRAY FOUNDATION BASE: The legs of the structures made with MS angles with zinc primer and at least 2 coats of aluminum paint

Any further corrigendum / amendments / addendums etc. shall be published in the Bank's website only. Interested applicants are requested to regularly visit the website for further updates.

The bidders should enclose a signed copy of this "Corrigendum" along with bid documents. There are no changes in other terms and conditions of the tender / RFP and the last date of submission of tender remains unchanged.

Authorized Signatory



Date: 26.09.2024

सामान्य प्रशासन अनुभाग,
तृतीय तल, अंचल कार्यालय, पुणे,
एफ.पी. ७९० (पार्ट), मंगला सिनेमाघर के निकट,
शिवाजी मार्ग, शिवाजी नगर,
पुणे, महाराष्ट्र - ४११००५.

General Administration Section,
Third Floor, Circle Office, Pune,
FP 790 (Part), Near Mangala Theatre,
Shivaji Road, Shivaji Nagar,
Pune, Maharashtra - 411005.

दुभा / Tel: ०२०-२५५३०६२२ / 020-25530622
ईमेल / Email: pecopne@canarabank.com