	ESTIMATE FOR ELECTRICAL WORKS AT: BRANCH AT CANARA BAN	ANK, DTC PATPARGANJ DELHI BRANCH			
S. NO.	DESCRIPTION OF ITEM	QTY	UOM	RATE (Rs.) (Excl. GST)	AMOUNT (Rs.) (Excl. GST)
1	SITC of 3 Nos. 200 Amp. Kit-kat Fuse unit along with 200 Amp. neutral link on wooden board of size 2'0" x 2'0" complete with connections complete in all respect to the satisfaction of Bank.		Set		
2	ELECTRICAL PANEL  Design, manufacture, providing, storing & installing in position, effecting proper connection, testing and commissioning of panel made of 16 SWG, CRCA sheet steel. It shall be dust and vermin proof. It shall have compartmentalized construction with bus bar chambers, cable alley, cable glands plate etc. as required, duly painted from inside as well outside. It shall have the following:  MAIN PANEL:  1 No.100 Amp. TPN, MCCB (25 KA breaking capacity), Bus bars 100 Amp., 3 phase, 4 strips, 415 volts, 50 Hz. copper busbars with colour coded PVC heat shrinkable sleeves. There should be 2 sets of BUS BAR in such a way that AC load should not be connected to GENERATOR power.  100 Amp. Changeover Switch Instruments: Digital Multi function Meter of standard make for displaying Input Voltage, Ampere, Power factor, KWH used with CTs.		No.		
	OUTGOING:  3 Nos. 32 Amp. TP MCB (For LDB, PDB, Branch UPS, Inverter and Spare Feeder) from Generator Powered Bus.  2 Nos. 63 Amp. TP, MCB (For AC DB and Spare Feeders) from Non-Generator Powered Bus.  5 Nos. 32 AMP DP MCB. 3 Nos (for Glow Sign board, Strong Room, and spare feeder) from Generator Powered Bus.  The design of panel should be got approved by the Architect before manufacturing. Also, the provision for 1/2 spare outgoings should be considered for future expansion. The job shall be completed to the satisfaction of the Bank.				
3	UPS I/P, O/P AND DISTRIBUTION & INVERTER INPUT & DISTRIBUTION				
a.	SITC of 32/40 Amp. TP MCB in encloser Double Door complete (Branch and Inverter Incomers) complete in all respects as required.	3.00	Nos.		
b.	SITC of 20/32 AMP Modular plug & socket along with MCB & plug top complete as per requirement and satisfaction of Bank. (2 for Branch's UPS Input, 2 for Branch's UPS Output)		Nos.		
c.	SITC of 12 WAY SPN Double Door DB complete with 1 No. 40 AMP DP MCB as incomer and 12 NOS. 6-10 AMP SPMCB as outgoing for Branch UPS power distribution to Computer points on Staff Counters / Tables.		No.		
d.	SITC of 8 WAY SPN Double Door DB complete with 1 No. 32 AMP DP MCB as incomer and 6 NOS. 6-10 AMP SPMCB as outgoing for UPS power distribution points for ESSENTIAL LODAS like CCTV System, Fire & Burglar Alarm Systems, Networking Rack, ATM and select Light points powered by UPS.	1.00	No.		
4	RAW POWER & FAN, LIGHTING DB & AC DISTRIBUTION BOARD				
a.	SITC of 4 WAY HTPN DB IP43,lko9, complete with 1 No. 63 AMP TP MCB as incomer and 12 NOS. 6-32 AMP. SPMCB for out going as LDB, complete in all respect as required.		Nos.		
b.	SITC of 6 WAY HTPN DB IP43,lko9, complete with 1 No. 63 AMP TP MCB as incomer and 18 NOS.18/20 AMP. SPMCB for out going as PDB & AC DB complete in all respect as required.		Nos.		
5	CARLES				
<u> </u>	All cables / wires shall be routed through PVC conduits / bends / elbows etc., as required, of appropriate dia. The conduits shall be clamped firmly to the walls / columns / pillars etc. with clips / clamps and fasteners rigidly even if above false ceiling.				
	Complete job shall include cutting chiseling in walls, floor and making good of all chases / cuts etc. with combination of cement-mortar, including painiting with type and shade of existing wall. The work shall be completed to the satisfaction of Bank.  NO CABLE / WIRE / CONDUIT SHALL BE VISIBLE IN THE BRANCH HALL / CUSTOMER LOBBY / STAFF WORKING AREA.				

SITC of 3.5 Core 50.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required.		Mtr.		
SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required.		Mtr.		
SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB				
(c) Branch UPS input power supply.  Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4	38.00	Mtr.		
SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS		Mtr.		
SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter	50.00	Mtr.		
SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required.	40.00	Mtr.		
SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter	42.00	Mtr.		
AC (Split and Cassette ) POINT				
SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split ACs) The wiring shall be done form DB to indoor or outdoor as per requirement	5.00	Nos.		
EARTHING				
Preparation and commissioning of earth pits with PIP technology GEL type 50mmdia 3000mm long earth electrod. (One Dedicated Earthing for ATM UPS, Branch UPS and main panel		Nos.		
SITC of Earthing conductor from earth terminal to load point with 6.0 sq mm multstrand copper conductor FR pvc /XLPE insulated cable in required dia pvc conduit complete in all respect as required.		Mtr.		
LIPS POINT	11 00	Nos		
Supply & Installation of point wiring for UPS or stabilized power plug points on workstations / table for computers using 3 X1.5 Sq.mm copper conductor multi starnd FR PVC sheathed flexible wire including PVC conduite laid floor raceways/conduit and taken upto table top using PVC rigid or flexible conduits run within wooden/metal partitions. Each point consisting of 1 No. Phase Indication light,3 Nos 6A, 5/6 pin sockets & wired together forming one point. The earth wire of green color only.		1100.		
RAW POWER POINT				
Same as serial no.1, but providing power point by using 2*4.00 sq.mm. PVC insulated 1100 V grade copper conductor wire with independent 1*4.0 sq.mm earth wire from D.B. to first point (Primary Point) and first to second point with 2*2.5 sq.mm. PVC insulated 1100 V grade copper conductor wire and 1*2.5 earth wire (Secondary Point). All wiring is to be provided in PVC conduit of suitable size. Each power point (Primary or Secondary) must include providing and fixing of a dual socket combination of 1 no. 16 Amp 6 –pin socket with 16 Amp. switch & 1 no. 6 Amp 5-pin socket with 6 Amp. switch. The switches should be Modular type switch / socket / plate etc. complete assembly).				
	service line connection up to Kit kat fuse unit complete in all respect as required.  SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required.  SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply.  Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS DISTIC of 2 runs of 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (a) AC DB (b) Inverter SITC of Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 no. 0.2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required.  SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to inverter  AC (Split and Cassette) POINT  SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor wire from selector switch to inverter  AC (Split and Cassette) POINT  SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm SpMCB complete in all respect as required by the Bank (for 1.0 1.5 Th-IW-all Split ACs) The wiring shall be done form DB to indoor or outdoor as per requirement at site EARTHING  Preparation and commissioning of earth pits with PIP technology GEL type S0mmdia 3000mm long earth electrod. (One Dedicated Earthing for ATM UPS, Branch UPS and main panel  SITC of Earthing conductor from earth terminal to load point with 6.0 sq mm multistrand copper conductor from earth terminal to load point with 6.0 sq mm such stand FR PVC sheathed flexible wire including PVC conduite laid floor raceways/cond	service line connection up to Kit kat fuse unit complete in all respect as quired.  SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as quired.  SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply.  Note: In case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm Cable  SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sqmm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS and to (a) AC DB (b) Inverter  SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) AC DB (b) Inverter  SITC of 5 Sub main Wiring for Strong room, Single Phase AC and Glow Sign Board with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor Fx pvc / xipe insulated Wire in required dia pvc conduit complete in all respects as required.  SITC of 2 runs of 10.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper Wire & Modular plug & Socket with 10/16/25 Amp. SPMCB complete in all respect as required by the Bank (for 1.0 / 1.5 Tr Hi-Wall Split at site  EARTHING  Preparation and commissioning of earth pits with PIP technology GEL type Sommdia 3000mm long earth electrod. (One Dedicated Earthing for ATM UPS. Branch UPS and main panel  SITC of Earthing conductor from earth terminal to load point with 6.0 sq mm multistrand copper conductor FR pvc / XLPE insulated cable in required dia pvc conduit complete in all respect as required by the purple of the purpl	service line connection up to Kit kat fuse unit complete in all respect as 35.00 Mtr. required.  SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as required.  SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel to (a) LDB (b) PDB (c) Branch UPS input power supply.  Note: In case inverter is present at the branch, the wirring from LDB should be with 2x6.0+1x2.5 sq.mm wirring mentioned below and not with 4 core 6.0 Sq.mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC insulated Multistrand Copper conductor wire from selector switch to UPS to UPS DIStribution boards  SITC of 4 core 10.0 Sq.mm Copper conductor Unarmoured Cable from main Panel / Non Generator power Bus to (a) ACDB (b) Inverter SITC of 4 core 10.0 Sq.mm and 1 no. 0.2.5 Sq.mm Multistrand Copper conductor FR pvc/ xlpe insulated Wire in required dia pvc conduit complete in all respects as required.  SITC of 2 runs of 10.0 Sq.mm and 1 no. 0.2.5 Sq.mm Multistrand Copper conductor wire from selector switch to inverter  AC (Split and Cassette ) POINT  SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor wire from selector switch to inverter  AC (Split and Cassette ) POINT  SITC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor wire from selector switch to inverter  AC (Split and Cassette ) POINT  SITC of Earthing conductor from earth terminal to load point with 6.0 sq mm multistrand copper conductor wire from selector wire virily in the conductor wire with 1 stile EARTHING  Preparation and commissioning of earth pits with PIP technology GEL type 50mmdia 3000mm long earth electrod. (One Dedicated Earthing for ATM UPS, 2.00 Nos. Stranch UPS and main panel  SITC of Earthing conductor from earth terminal to load point with 6.0 sq mm multistrand copper conductor from earth terminal to load point with 6.0 sq mm multistrand copper conductor wire with indep	Service line connection up to Kit kat fuse unit complete in all respect as a 5.00 Mtr. required.  SITC of 3.5 Core 35.0 Sq.mm Aluminium conductor Armoured Cable for service line connection up to Kit kat fuse unit complete in all respect as 45.00 Mtr. SITC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel lo 3 LDB SiTC of 4 core 6.0 Sq.mm Copper conductor Unarmoured Cable from main Panel lo 3 LDB Sit Polar UPS input power supply.  Note: in case inverter is present at the branch, the wiring from LDB should be with 2x6.0+1x2.5 sqmm wiring mentioned below and not with 4 core 6.0 Sq.mm and 1 no. of 2.5 Sq.mm FRLS PVC Insulated Multistrand Copper conductor wire from selector switch to UPS to UPS 35.00 Mtr. SITC of 4 core 10.0 Sq.mm Cable SITC of 2 runs of 6.0 Sq.mm and 1 no. of 2.5 Sq.mm Multistrand Copper conductor Wire from selector switch to UPS to UPS 35.00 Mtr. SITC of 4 core 10.0 Sq.mm and 1 no. 2.5 Sq.mm Multistrand Copper conductor Wire from selector switch to UPS to UPS 35.00 Mtr. SITC of 2 runs of 10.0 Sq.mm and 1 no. 2.5 Sq.mm Multistrand Copper conductor Wire from Selector switch to inverter and the conductor Ryport xips insulated Wire in required dia pvc conduit complete in all respects as required.  SITC of 2 runs of 10.0 Sq.mm and 1 no. 2.5 Sq.mm Multistrand Copper conductor Ryport xips insulated Wire in required dia pvc conduit complete in all respects as required.  Mitr. StiTC of AC Point Wiring with 2 No. 4.0 Sq.mm and 1 No. 2.5 Sq.mm Multistrand Copper conductor wire from selector switch to inverter and the stitus of the stit

	There shall be a maximum of 2 points per circuit			
	NOTE: The power point, complete as mentioned above, shall be placed on the			
	low ht. / full ht. partition above the tables / counters at a suitable place to			
	ensure convenient accessability for staff.			
	Primary Point	6.00	Nos.	
	Secondary Point	6.00	Nos.	
10	LIGHT/FAN POINT			
	Supply & Installation of concealed point wiring using 600v grade 1.5 Sq.mm copper conductor PVC insulated wires (with proper R,Y,B color code) pulled through heavy gauge PVC conduits laid concealed over false ceiling including 2 Nos. 2.5 sqmm circuit wires from the relevant DB and also including 2.5 sqmm green color copper earth wire and switch plate, switches, etc. as approved by the Bank's Engineer/Architect.			
a.	One light points controlled by one 6 amp. Modular switch.	38.00	Nos.	
b.	Two light points controlled by one 6 amp. Modular switch.  (Cost shall include wiring of the first point from the switch board and then looping from the first point to the second point)	28.00	Nos.	
c.	Ceiling Fan Point including the cost of 6A Switch along with 5 step electronic fan regulator.	4.00	Nos.	
d.	Wall Fan Point along with 6 AMP switch	9.00	Nos.	
e.	Exhaust Fan Point along with 6 AMP switch	3.00	Nos.	ļ
f.	Call Bell Point	1.00	Nos.	
11	FIXTURES			
	Supplying, installation with hanging support , testing and commissioning of following light fixtures with electronic Ballasts, Tubes, lamps, all fixing materials including connecting wires etc. all complete as per the directions of Engineer-in-charge.(all Commercial LED Light Fixures should be covered with minimum 3 Years onsite replacement warranty)			
a.	FULL GLOW 2X2 LED 36W Ultra slim Smart Panel complete with driver of make As specified in tender document or approved by bank	14.00	Nos.	
b.	LED 18/20 watt Tube Light with all accessories.make As specified in tender document or approved by ARCHITECT OR BANK	13.00	Nos.	
c.	supplying , fixing ,testing and commissioning of 15 W LED commercial type down lighter of make As specified in tender document or approved by ARCHITECT OR BANK	23.00	Nos.	
d.	Wall mounted fans 450 mm dia. make as specified in tender document or approved by ARCHITECT OR BANK	9.00	Nos.	
e.	Supply &fixing of Ceiling fans 1200 mm double ball bearing make As specified in tender document or approved by ARCHITECT OR BANK with required down rod and hanging arrangement	4.00	Nos.	
f.	Supply & fixing of 230 mm exhaust fan 'Ventilair DX W' with self closing louvers and plastic body with all accessories etc. complete of make As specified in tender document or approved by ARCHITECT OR BANK	3.00	Nos.	
g.	SITC of Call Bell.	1.00	No.	
	TOTAL FOR ELECTRICAL WORKS (EXCLUDING GST)			
Α	Discount If any (Only on Excluding GST amount only)			
	Net Amount (After Discount if any - Excluding GST) (Discount if any on Amount in Sub part (A -Excluding GST) Not on sub part	e given	 	
	GST as extra as applicable (For ELECTRICAL works) - By Bank			