

Sym.	Description
	Switch board
	5 A - 5 Pin Ele. Out let
	15 A - 5 Pin Ele. Outlet
	Computer socket out let.
	Server hub zone
	Distribution board
	U.P.S

NOTE-

(a) Distance between data cabling & computer circuit wiring root should be maintain 300MM horizontal or vertical as/required.

(b) Numbers of rows for power circuit laying/data cable laying either in wall /partition can be increase as/required & in the same root as shown in drawing.

(2x6+1.5) sqmm P.V.C insulated copper wire for U.P.S input;


(2x2.5+1x1.5) Sqmm P.V.C insulated copper conductor cable for computer power.

Cat 6 Data cable wire.

Note-Ckt Indicate number of circuit,2/3 PC can be connected in a circuit as Per EE. Identical number of circuit connected in same circuit/in a circuit.

**COMPUTER & DATA CABLE
CANARA BANK CHANDIL BRANCH**

Title-Computer & Data Cable
Ref No-Cd/Can/Cha/24-25
Date-08/07/24
Rev Date-30/07/24



M/S RAM LAKSHMAN & SKY ASSOCIATE
Architect, interior designer & Valuer
Flat No-101, Beta Block , Srinath residency
Marin drive road Kadma, Jamshedpur-831005
Email-yasharch18@yahoo.com
MO-9431932201 ,6203263491