

Sym.	Description
	Switch board
	5 A - 5 Pin Ele. Out let
	15 A - 5 Pin Ele. Outlet
	Computer socket out let.
	Server hub zone
	Distribution board
	U.P.S

- (2x6-1.5) sqmm P.V.C insulated copper wire for U.P.S. input;
- (2x2.5-1x1.5) Sqmm P.V.C insulated copper conductor cable for computer power.
- Ckt & Data cable wire.

Note-Ckt Indicate number of circuit, 2/3 PC can be connected in a circuit as Per EE. Identical number of circuit connected in same circuit/in a circuit.


NOTE-

- (a) Distance between data cabling & computer circuit wiring root should be maintain 300MM horizontal or vertical as/required.
- (b) Numbers of rows for power circuit laying/data cable laying either in wall/partition can be increase as/required & in the same root as shown in drawing.

**COMPUTER & DATA CABLE OF CAVARA BANK
SERAIKELLA BRANCH**

Ref No-Cd/Ser/24-25

Date-29/07/2024



M/S RAM LAKSHMAN & SKY ASSOCIATE
 Architect, Interior designer & Valuer
 Flat No-101, Beta Block, Shrath reastery
 Marlin drive road Kadma, Jammehd-pur-831006
 Email-ysheerach18@yahoo.com
 MO-9431893201 , 8203283491