

Layout is Approved Subject to compliance of observations made vide  
 Ref. No. 129/24-25  
 Date: 07/5/24


WHERE THE VENTILATION REQUIREMENT ARE NOT MET THROUGH NATURAL VENTILATION THE SAME CAN BE ENSURED THROUGH MECHANICAL VENTILATION

UPS ROOM PARTION IS CONSTRUCTED WITH CEMENT BOARD I.E. BISON BOARD WITH AL. FRAMES / AS PER TENDER.

CASH COUNTER SHOULD BE COVERED WITH ALUMINIUM GRILL FROM TOP  
 CASH COUNTER SHOULD BE CLOSED FROM ALL FOUR SIDES

CUSTOMER AREA = 254.98 SQ.FT.  
 BANKING HALL AREA = 598.08 SQ.FT.  
 CARPET AREA = 893.09 SQ.FT.

कृते केनरा बैंक / For CANARA BANK  
 मंडल प्रबंधक / Divisional Manager  
 सा.प्र. विभाग, प्र.का., बेंगलूरु - 560 004  
 G.A. Wing, H.O., BENGALURU - 560 004



DRAWN BY	DEVINDER
DATE	09-04-2024
TITLE	
PROPOSED VPO MAINA BRANCH	, ROHTAK HARYANA
DEVINDER & ASSOCIATES	ARCHITECT, INTERIOR DESIGNER
POCKET B/1A, PH-II LASHOK VIHAR,	
DELHI - 110052, 09810419468	
E.MAIL devinder_associates@yahoo.com	

OPTION - III

