

## CORRIGENDUM NOTICE

In continuation to our tender notice: **‘INTERIOR WORKS OF CIRCLE OFFICE AGRA’** on our website and paper advertisement dated 08.09.2020, the following points are hereby clarified:

S.No	Page	Tender Clause and Clause No/Point	Remarks
1	Furnishing BOQ		In case of any difference in BOQ and List of Make items, List of make items will supersede and will be given priority.
2	List of Make		The items mentioned in list of make are to be used only.
3	Electrical BOQ	Point No 13 280 Nos. telephone cable	280 nos. should be read as 280 rmtr.
4	Electrical NIT Page 4	Similar works means Electrical works for offices / residential /banks buildings including modular furnishing works.	It should be read " Similar works means Electrical works for offices / residential /banks Buildings"
5	Air Conditioners	List of approved companies	LG Indoor and outdoor units can also be used
6	Air Conditioners	Six 5.0 Ton AC to be supplied	No 5.0 Ton AC is to be supplied, 14 four Ton AC is to be supplied (Modified BOQ Attached)

---

7	Air Conditioners		The Cooling Capacity of the AC should be read as 100% Capacity at 43degree C and non stop cooling even at 56 degree C
---	------------------	--	-----------------------------------------------------------------------------------------------------------------------

Tender document can be downloaded from our bank's website – [www.canarabank.com](http://www.canarabank.com). The Bank reserves the right to accept or reject any or all the tenders without assigning any reasons thereof.

- Asst General Manager