

## CORRIGENDUM AND REPLY TO PRE-BID QUERIES

" SUPPLY, INSTALLATION, TESTING, COMMISSIONING & MAINTENANCE OF ON- GRID ROOFTOP SOLAR PHOTO VOLTAIC POWER (RTSP) GENERATION SYSTEM AT BANK OWNED/LONG LEASED PROPERTIES AT DIFFERENT LOCATIONS IN KOLKATA AND ONE LOCATION IN DURGAPUR (WEST BENGAL)"

Ref. No.: RFP/01/KOL/SOLAR/2022-23 DATED 16.04.2022  
PRE-BID MEETING HELD ON 30.04.2022

Following additional technical specifications incorporated for withstanding maximum wind speed of 200km/hr

1. Solar photovoltaic module should be made of 4 mm glass thickness.
2. Solar photovoltaic module glass holding aluminum frame should be minimum 35-40 mm.

**ALL OTHER RULES, DIRECTIONS, TERMS & CONDITIONS OF THE TENDER, REMAIN UNCHANGED**

Date: 04.05.2022

sd/-  
Deputy General Manager  
Canara Bank  
Circle Office Kolkata

