

INVENTORY /TAKE OFF SHEET FOR FIRE ALARM SYSTEM AT CANARA BANK AT SAKET NAGAR, BHOPAL									
S. No.	Description	Smoke Detector	Heat Detector	Response Indicator	Fault isolation	Hooter	Manual Call Point	25 mm ms Conduit	1.5 x 2 core sqmm
	CANARA BANK								
1.)	BASEMENT FLOOR	-	35.00	-	1.00	2.00	2.00	240.00	280.00
2.)	GROUND FLOOR	-	-	-	-	-	-	-	-
3.)	FIRST FLOOR	38.00	-	7.00	1.00	2.00	2.00	300.00	350.00
4.)	SECOND FLOOR	36.00	-	6.00	1.00	2.00	2.00	282.00	329.00
5.)	THIRD FLOOR	36.00	-	6.00	1.00	2.00	2.00	282.00	329.00
6.)	TERRACE FLOOR	-	-	-	-	-	-	-	-
	<b>TOTAL</b>	<b>110</b>	<b>35</b>	<b>19</b>	<b>4</b>	<b>8</b>	<b>8</b>	<b>1,104</b>	<b>1,288</b>