

CANARA BANK

Premises & Estate section, Circle Office 2nd Floor, B-Wing, Plot-C-14, G-Block,
Bandra Kurla Complex, Bandra(E), Mumbai- 51.

Tel- 26728465, 26728464, e-mail- emcomcity@canarabank.com

“Minutes of meetings held on 31/08/2020 for Tender for Civil & Structural Repair and Painting works in Canara Bank Residential Complex, Madhav-Mukund Building, Mahakali Caves Road, Andheri(E), Mumbai.”

Date: 01/09/2020

Tender Reference No. 07/MCPE/2020

Members Present from Bank

1. Sri. Vidhresh Kumar :: Technical Manager
2. Sri. Surya Pratap Mishra :: Officer

Bidders Representative Present From:

1. M/S Mahendra Realtors & Infrastructure Pvt. Ltd.
2. M/S Manibhadra Associates
3. M/S Heeren & Co.
4. M/S Aziz & Associates P. Ltd


The Clarification for the queries raised by the bidders and corrigendum to certain clauses in tenders are enclosed herewith.

This Corrigendum shall form part of and shall be read with Tender/ Contract documents and shall become part of the contract and shall be signed on every page and enclosed with the bid.

In case of any discrepancy between the corrigendum and other tender/ Contract documents, the corrigendum shall prevail.

All the tender terms & conditions other than those modified in this corrigendum remain unchanged.

Yours Faithfully



HEMANT TASKHEDKAR
DIVISIONAL MANAGER



Tender Ref. No: 07/MCPE/2020


Tender for Civil & Structural Repair, Internal Repair and Painting works in Canara Bank Residential Complex, Madhav-Mukund Building, Mahakali Caves Road, Andheri(E), Mumbai.

CORRIGENDUM FOR TENDER DOCUMENTS

S.N.	PAGE NO.	CLAUSE NO.	DESCRIPTION	CORRIGENDUM
1.	BOQ	C.1 c	<p>POLYMER MODIFIED MORTAR (PMM) : Providing and repairing the damaged concrete portion with single component, fibre reinforced, dual shrinkage-compensated , thixotropic, cementitious patch repair mortar as per manufacture's specifications in thickness of 12mm to 50mm both vertical & overhead depending on site conditions in layers capable of applying 25mm thick initially by hand and finishing with trowel, compacting the same around bars and finishing in line with existing concrete surface, after applying bonding coat as directed by Engineer in charge / Architect / Employer.(bonding coat shall be payable separately). The rates are inclusive of Manpower, Material and Equipment.The approved brands are Emaco S48CT of BASF/ Renderoc S2 of Fosroc/ReCon GP 40 of Conmix or equivalent material that achieves compressive strength of 35 MPa at 7 days. (The rate of item to be quoted inclusive of C1. a, b, c & d).</p>	<p>POLYMER MODIFIED MORTAR (PMM) : Providing and repairing the damaged concrete portion with single component, fibre reinforced, dual shrinkage-compensated , thixotropic, cementitious patch repair mortar as per manufacture's specifications in thickness of 12mm to 50mm both vertical & overhead depending on site conditions in layers capable of applying 25mm thick initially by hand and finishing with trowel, compacting the same around bars and finishing in line with existing concrete surface, after applying bonding coat as directed by Engineer in charge / Architect / Employer.(bonding coat shall be NOT be payable separately). The rates are inclusive of Manpower, Material and Equipment. The approved brands are Emaco S48CT of BASF/ Renderoc S2 of Fosroc/ReCon GP 40 of Conmix or equivalent material that achieves compressive strength of 35 MPa at 7 days. (The rate of item to be quoted inclusive of C1. a, b, c & d).</p>
2.	BOQ	C.2	<p>MICROCONCRETE: Same items as stated in C1.a, C1.b & C1.c shall be executed in addition to the following specifications. Providing and laying of prepacked dual shrinkage compensated polymer modified microconcrete like Master Emaco S346 of BASF / Renderoc LA55 of Fosroc / SikaRep Microcrete-4 of Sika or equivalent material. Pouring in narrow locations. (Rate includes the formwork, materials, labour etc. Measurement on the basis of actual consumption of microconcrete). The item has to be executed for columns, beams , Slabs etc. depending upon the site conditions, complete as specified and as directed by Engineer in charge / Architect / Employer.</p>	<p>MICROCONCRETE: Same items as stated in C1.a, C1.b shall be executed in addition to the following specifications. Providing and laying of prepacked dual shrinkage compensated polymer modified microconcrete like Master Emaco S346 of BASF / Renderoc LA55 of Fosroc / SikaRep Microcrete-4 of Sika or equivalent material. Pouring in narrow locations. (Rate includes the formwork, materials, labour etc. Measurement on the basis of actual consumption of microconcrete). The item has to be executed for columns, beams , Slabs etc. depending upon the site conditions, complete as specified and as directed by Engineer in charge / Architect / Employer.</p>



SURYA PRATAP MISHRA
OFFICER



VIDHNESH KUMAR
MANAGER



HEMANT TASKHEDKAR
DIVISIONAL MANAGER

