



| Supply, Installation, Testing, Commissioning & Maintenance of 111 kWp (consolidated) ON-GRID Rooftop Solar Photo Voltaic Power Plant at our Offices/ Branches in Hubballi Circle.   |                  |   |  |  |
|---|------------------|---|--|--|
| Corrigendum 1 to RFP Ref. No. HUB/RTSP/2/2022 dated 14.04.2022  |                  |   |  | Date:04.05.2022  |
| The Pre-Bid meeting for the captioned tender was held on April 25, 2022 at 3 PM at Circle Office, Hubballi. The queries raised by the prospective bidders and the clarification/replies given by the Bank are given as under. |                  |   |  |  |
| S.No  | Tender Clause No | Tender clause   | Points / Queries raised by the prospective bidders   | Bank's Clarifications/ Replies                             |
| 1   | 26.1             | Procurement through MSEs (Micro & Small Enterprises) will be done as per the Policy guidelines issued by the Ministry of Micro, Small & Medium Enterprises vide Gazette notification no. D.L.-33004/99 dated 23.03.2012 and as amended from time to time. Following are the conditions applicable as per the Government of India Guidelines   | If Any Supplier is the MSE Company and the Startup (and As they are MSE and New Start up and not having the MNRE registration on their name but they are ready to supply the material by procuring from Supplier who is MNRE Empaneled company ) . And if they are not having the technical qualification with them and they are having the financial Qualification with them. Can they allowed to bid in the said tender by getting the benefit of the MSE & Startup? | Not allowed.   |
| 2   | 26.1.2           | MSEs participating in tenders, quoting price within price band of L1+15% shall also be allowed to supply a portion of requirement by bringing down their price to L1 in a situation where L1 price is from someone other than MSE & such MSE shall be allowed to supply at least 20% of total tendered value. In case there are more than one MSEs within such price band and agree to bring down their price to L1, the 20% quantity is to be distributed proportionately among these Bidders. | And as if we are MSE and new startup and if we are L1; No other bidder is ready to match the price, then can 100 % capacity is allotted to L1 Bidder.  | Yes. In such case, 100 % capacity is allotted to L1 Bidder |

| Supply, Installation, Testing, Commissioning & Maintenance of 111 kWp (consolidated) ON-GRID Rooftop Solar Photo Voltaic Power Plant at our Offices/ Branches in Hubballi Circle. |                            |   |  |  |
|---|----------------------------|---|--|--|
| 3   | Appendix II                | <p>"ii). No mobilization advance amount will be paid to the firms. Payments to the contractor will be regulated as below:</p> <p>a) 65 % of the cost of equipments against supply / delivery of equipments at site, duly unpacked and supported by necessary documents / test certificates etc, and certification of Engineer in charge.</p> <p>b) 30 % upon installation, commissioning and upon handing over of the solar power plant after successful testing &amp; commissioning at site.</p> <p>c) 5% at the end of the warranty period of 1 year; this can be released against Bank guarantee for equivalent amount in favour of the Bank for the warranty period in approved Bank's format."</p> | <p>We request you to revise the payment terms as follows:</p> <ol style="list-style-type: none"> <li>1. 10% Advance Payment. (We will provide BG for 10% Payment).</li> <li>2. 50% on against material receipt on site.</li> <li>3. 30% on against Erection, Installation of the Solar Power Plant.</li> <li>4. 10% payment will be made on satisfactory commissioning.</li> </ol> | The referred tender clause holds good.   |
| 4   | Appendix II                | 60 days from the 14th day from the date of work order issued by the Bank including mobilization period  | We request you kindly amend Completion period as 120 days.   | 90 days from Acceptance of work order by the vendor including mobilization period.   |
| 5   | SCOPE OF COMPREHENSIVE AMC | 4. The Comprehensive Annual Maintenance Charges shall be paid once in six months in advance subject to satisfactory maintenance for the period of previous one year and on production of Bank guarantee equivalent to the amount paid in advance .  | <p>We request you to kindly revise as:</p> <p>The Comprehensive Annual Maintenance Charges shall be paid once in three months in advance subject to satisfactory maintenance of previous quarter.</p>  | The Comprehensive Annual Maintenance Charges shall be paid once in three months in advance subject to satisfactory maintenance of previous quarter and on production of Bank guarantee equivalent to the amount paid in advance. |

| Supply, Installation, Testing, Commissioning & Maintenance of 111 kWp (consolidated) ON-GRID Rooftop Solar Photo Voltaic Power Plant at our Offices/ Branches in Hubballi Circle. |   |  |   |   |
|---|---|--|---|---|
| 6   | Technical specifications of SPV Power Plant |  | Kindly Confirm the Offer Validity days.   | The tender for the works shall remain open for acceptance for a period of 120 days from the date of opening of price bids, the rates and terms pertaining to rates shall be as per our price bid.   |
| 7   | Technical specifications of SPV Power Plant | 3. In case of grid failure, the standby inverter shall create a captive grid and SPV power keeps feeding to this captive grid.   | As per tender, On grid Inverter is required. If power grid failure, On grid inverter will automatically turn off. Kindly confirm Inverter is Hybrid Inverter or Grid Tie Inverter.      | Grid tie inverter is to be provided. In case of grid failure, solar inverter should automatically cut off flow of power from SPV plant to the grid.   |
| 8   | Technical specifications of SPV Power Plant | The bus bars shall be made of copper of desired size. Suitable capacity MCBs along with necessary surge arrestors shall be provided for controlling the DC power output to the PCU/Inverter. | On grid is Inverter will have Inbuilt isolators. So don't need additional MCB's. Hence Kindly remove DCDB Clause.   | The referred tender clause holds good.  |
| 9   | Technical specifications of SPV Power Plant | Cables should be FRLS PVC insulated Copper Conductor armoured Cables of 1100 V   | Kindly consider DC cables as copper material and AC cables as Aluminium material.   | Cables should be FRLS PVC insulated Copper Conductor armoured Cables of 1100 V Grade for DC power supply and copper conductor/Aluminium conductor power cables for AC power. Cables shall conform to IS: 1554 / IEC 60502/1.S 7098 ( Part -1) 1988 AND IS 694 / IEC 60227 |
| 10  | Technical specifications of SPV Power Plant | There shall be the required number of suitable lightning arrestors (ESE) installed in the array area.  | As plant capacities are smaller, we can use conventional type Lightning Arrestors instead of ESE type. Hence kindly remove ESE type and consider Conventional type Lightning Arrestors. | There shall be the required number of suitable lightning arrestors installed in the array area.   |

| Supply, Installation, Testing, Commissioning & Maintenance of 111 kWp (consolidated) ON-GRID Rooftop Solar Photo Voltaic Power Plant at our Offices/ Branches in Hubballi Circle. |   |   |   |  |
|---|---|---|---|--|
| 11  | Technical specifications of SPV Power Plant | The array structure shall be made of hot dip galvanized MS angles/anodized aluminum of size not less than 50 mm x 50 mm x 6 mm size. The minimum thickness of galvanization shall be at least 80 microns. | Kindly consider Pre galvanized sheet metal.                 | The referred tender clause holds good.   |
| 12  | Technical specifications of SPV Power Plant | The system shall be capable of automatic operation with automatic wake-up in the morning and providing supply to the load after synchronizing with Grid/DG supply.  | Kindly confirm Reverse Power Flow Relay is required or not. | The system shall be capable of automatic operation with automatic wake-up in the morning and providing supply to the load after synchronizing with Grid supply. D.G power supply will not be linked with SPV power supply. |
| 13  | 7. Date of submission<br>8.Date of opening  | Sealed envelopes to be submitted on or before 05.05.2022 up to 3.00 PM.<br>Technical & Commercial Bid will be opened on 05.05.2022 at 3.30 PM   |   | Sealed envelopes to be submitted on or before 16.05.2022 up to 4.00 PM.<br>Technical & Commercial Bid will be opened on 16.05.2022 at 4.30 PM  |